

Standard Screen
Alarm Frequency Display

Sample Screen Manual

Mitsubishi Electric Corporation

Using the Samples

The sample screen data and files such as the instruction manual can be used upon agreement to the following matters.

- (1) This data is available for use by customers currently using or considering use of Mitsubishi products.
- (2) The intellectual property rights of the files provided by Mitsubishi (hereinafter referred to as the "Files") belong to Mitsubishi.
- (3) Alteration, reproduction, transfer or sales of the Files is prohibited.
This does not apply when the content, in part or full, is used for Mitsubishi products incorporated in a device or system created by the customer. Furthermore, this does not apply to the transfer, reproduction, reference or change of layout in the specifications, designs or instruction manuals of built-in products prepared by the customer using Mitsubishi products.
- (4) Mitsubishi will not be held liable for any damages resulting from the use of the Files or the data extracted from the Files. The customer is responsible for all use.
- (5) If any usage conditions are appended to the Files, those conditions must be observed.
- (6) The Files may be deleted or the contents changed without prior notice.
- (7) When using the Files, please always read the corresponding manuals and related manuals indicated therein. Please pay special attention to safety, and correctly handle the product.

CONTENTS

REVISIONS4

1. OUTLINE.....5

 1.1 Reusing Standard Screen Samples5

2. SYSTEM CONFIGURATION5

3. GOT.....5

 3.1 System Applications That Are Automatically Selected.....5

 3.2 Controller Setting of Screen Design Software.....5

 3.3 Ethernet Setting of Screen Design Software.....5

4. SCREEN SPECIFICATIONS6

 4.1 Display Language.....6

 4.2 Screen List/Transition.....6

 4.3 Explanation of Screens.....7

 4.3.1 Alarm Frequency Display 1(B-30001).....7

 4.3.2 Alarm Frequency Display 2(B-30002).....8

 4.4 Device List9

 4.5 Comment List9

5. TEMPLATES.....10

REVISIONS

Sample Screen Manual

Date	Control No.*	Description
2014/8	BCN-P5999-0301	First edition

* The Control No. is noted at the lower right of each page.

Project Data

Date	Project data	GT Designer3*	Description
2014/8	Alarm-Frequency_V_Ver1_E.GTX	1.117X	First edition

* The version number of screen design software used to create the project data is listed. Please use the screen design software with the listed version or later.


1. OUTLINE

This manual explains the sample screens of GOT2000 connected to a MELSEC-Q Series PLC (Q06UDEHCPU) via Ethernet, which can be used to display the number of alarm occurrences for each item.

1.1 Reusing Standard Screen Samples

Standard screen samples include multiple patterns of screens that can be used by the customers depending on the intended use. Screens should be reused for the customers screen data by using [Utilize Data (Screen)]. For more details about [Utilize Data (Screen)], please refer to the "GT Designer3 (GOT2000) Help".

2. SYSTEM CONFIGURATION



*1: For more details about the cable, please refer to the "GOT2000 Series Connection Manual (Mitsubishi Products)".

3. GOT

3.1 System Applications That Are Automatically Selected

Type	System application name		
Standard Function	Standard System Application		
	Standard Font	Japanese	
Communication Driver	Ethernet Connection	Ethernet(MELSEC),Q17nNC,CRnD-700, Gateway	
Extended Function	Standard Font		Chinese (Simplified)
	Outline Font	Gothic	Alphanumeric/Kana
			Japanese (Kanji)
			Chinese (Simplified)

3.2 Controller Setting of Screen Design Software

Detail Setting

Item	Set value	Remarks
GOT NET No.	1	
GOT Station	2	
GOT Standard Ethernet Setting	Refer to table below	
GOT Communication Port No.	5001	
Retry (Times)	3	
Startup Time (Sec)	3	
Timeout Time (Sec)	3	
Delay Time (ms)	0	

GOT Standard Ethernet Setting

Item	Set value	Remarks
Reflect GOT Standard Ethernet setting in the GOT	Checked	
GOT IP Address	192.168.3.18	
Subnet Mask	255.255.255.0	
Default Gateway	0.0.0.0	
Peripheral S/W Communication Port No.	5015	
Transparent Port No.	5014	

3.3 Ethernet Setting of Screen Design Software

	Host	Net No.	Station	Unit Type	IP Address	Port No.	Communication
1	*	1	1	QnUD(P)V/QnUDEH	192.168.3.39	5006	UDP


4. SCREEN SPECIFICATIONS

4.1 Display Language


The language of the text displayed on the screen can be switched between Japanese, English and Chinese (Simplified). The text strings in each language are registered in the columns No.1 to No.3 in the comment groups No.341 and No.342 as shown below. When the column No. is set in the language switching device, the language corresponding to the column No. will appear.

Column No.	Language
1	English
2	Japanese
3	Chinese (Simplified)

4.2 Screen List/Transition




Base screen B-30001 : Alarm Frequency Display 1



Base screen B-30002 : Alarm Frequency Display 2

4.3 Explanation of Screens

4.3.1 Alarm Frequency Display 1(B-30001)



Outline

This screen displays the number of alarm occurrences and resets the number of alarm occurrences for each alarm target.


Description

1. Displays the content of alarm and the number of alarm occurrences.
2. Clear the number of alarm occurrences.
3. The switch indicates the currently displayed screen, thus selecting this switch will not switch screens.
4. Shows unused switches for base screen switching.
5. Switches to the previously opened screen.
6. Switches languages.

Remarks

- To the switches marked with No.6, settings are made to switch system languages in conjunction with the change of the display language.
- For each alarm target, please create ladder programs for incrementing the number of alarm occurrences.

4.3.2 Alarm Frequency Display 2(B-30002)



Outline

This screen displays the number of alarm occurrences for each alarm target.

Description

1. Displays the content of alarm and the number of alarm occurrences.
2. The switch indicates the currently displayed screen, thus selecting this switch will not switch screens.
3. Shows unused switches for base screen switching.
4. Switches to the previously opened screen.
5. Switches languages.

Remarks

- To the switches marked with No.5, settings are made to switch system languages in conjunction with the change of the display language.
- For each alarm target, please create ladder programs for incrementing the number of alarm occurrence.

4.4 Device List

Some of the devices specified to the on-screen switches and lamps, etc., are also used for common settings of functions such as scripts. Using [Batch Edit] is recommended to change these devices in a batch. For more details about using [Batch Edit], please refer to the "GT Designer3 (GOT2000) Help".

4.4.1 Devices of the controller

Type	Device No.	Application
Bit	Not used	
Word	D0 to D15	For Alarm Frequency Display

4.4.2 GOT internal devices


Type	Device No.	Application
Bit	Not used	
Word	GD60000	Base Screen Switching
	GD60021	Language Switching
	GD60022	System Language Switching

4.5 Comment List

Comment group No.	Where comments are used
341	B-30001
342	B-30002

5. TEMPLATES


Templates are a group of figures and objects. Related settings are grouped into template attributes and registered, so the devices and colors, etc. can be easily changed in a batch. For more details about changing the attribute settings, please refer to the "GT Designer3 (GOT2000) Help".



The template information is only displayed on the screen design software's editing screen. It is not displayed on the GOT display screen.

Example: Changing the color of switches (Each Screen)

(1) Select [Template Information], and click on [Template Property] (or double-click [Template Information]).



The figures and objects that are registered in the template are changed to the selected state.

(2) Double-click on [Setting Value] of [Switch(Each Screen)_Shape Color], and select the new color.

